

Bristol Township Chimney Check List	Property Owner Name:
	Property Street Address:
	City, State, Zip:

COMPLETE ALL APPLICABLE SECTIONS

OK (is acceptable)	F (fail, not acceptable) any F's Must Be explained or repaired	N/A (does not apply)
--------------------	--	----------------------

Oil Flue Chimneys	OK, F or N/A	Zero Clearance Fireplace	OK, F or N/A
Proper size to NFPA 31 or Manufacturers Specifications		Chimney meets NFPA 211, 2 ft, 3 ft, 10 ft rule	
Chimney meets 2 ft, 3 ft, 10 ft rule		Clearance to combustibles visible	
Thimble Area clearance and condition		Hearth extension 6 sq ft or less 8" sides 16" front	
Condition of connector pipes and accessories		Hearth extension over 6 sq 12" sides 20" front	
Crown wash and flashing		Clearance to mantle and trim	
Listed cap for chimney system		Appliance condition/masonry panel's firebox	
Masonry chimney condition of flue liner		Damper condition	
Class A chimney free from dents and buckling		Cap and chase flashing	
Clean out door or tee cap		Chimney free from dents/buckling/cleanliness	
Clearance of connector pipes		Chase siding/stucco free warping	
Length of connector pipes			
Chimney cleanliness			
Gas B Vent			
Vent cleanliness			
Proper sizing to NFPA 54 or Manufacturers Specifications			
Clearance of connector pipes			
Property manifold			
Condition of vent (free from rust & dents)			
Flashing from storm collar			
Vents meets heights as per NFPA 54			
Draft hood and damper			
Clean out tee			
Clearance to vent			

Masonry Fireplaces	OK, F or N/A	Wood/Coal Stove Inserts	OK, F or N/A
Hearth extension 6 sq or less 8" sides 16" front		Clearance plate on vent UL listed or to NFPA 211 standards	
Hearth extension over 6 sq 12" sides 20" front		Clearance and condition to connector pipes	
Proper spark arrestor		Condition of appliance	
Proper flue size and condition of flue liners		Proper thimble area clearance	
Proper smoke chamber size and condition		Proper wall or ceiling support Class A chimney	
Chimney cleanliness		Chimney flue condition	
Condition of the crown		Proper spark arrestor	
Condition of the flashing		Chimney meets 2 ft, 3 ft, 10 ft rule	
Proper clearance to combustibles that are visible		Proper clearance of the appliance	
Fire box condition mortar joints		Chimney connector accessories (barometric damper)	
Condition of damper/top mount damper		Proper hearth and back drop	
Metal box grill openings		Cleanout tee on door	
Proper clearance to mantel & trim		Class A chimney clearance to combustibles that are visible	
If cleanout door installed, condition of door		Masonry chimney clearance that is visible	
Chimney meets 2 ft, 3 ft, 10 ft rule		Direct connection to chimney flue	
Lintel area filled with mortar		Chimney cleanliness	
Natural gas logs, licensed plumber to check gas lines		Proper bracing of Class A chimney	
Fireplace wood inserts direct connection to flue liners installed to manufacturers specification, or NFPA standards		Connector pipes same size off the branch of the unit 8" units must have 8" chimney	
Levittown Jubilee			
Fire wall modification in place			

Comments:

Chimney Company Name:	Contractor Registration Number:
Chimney Company Address:	Certification Valid Thru:
Inspector Name (Print):	
Inspector Signature:	Date of Inspection: